

COMBINATION TABLES

Outdoor unit: MU2-Y 53M (DUAL)

OUTDOOR UNIT	INDOOR UNIT		COOLING CAPACITY [KW]		TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
	TO	B	TO	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 53M (1x1)	20M 8.000	—	2,30	—	1,43	2,00	2,90	0,35	0,60	0,75	1,52	2,60	3,24	3,35	—	—	—	—
	27M 9.000	—	2,50	—	1,43	2,50	3,20	0,35	0,75	0,93	1,52	3,24	4,06	3,35	—	—	—	—
	35M 12.000	—	3,50	—	1,43	3,50	3,90	0,35	1,08	1,29	1,52	4,68	5,62	3,25	—	—	—	—
	53M 18.000	—	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89	1,96	6,73	8,20	3,23	—	—	—	—
	20M 8.000	20M 8.000	2,30	2,30	2,12	5,00	5,62	0,54	1,47	2,05	2,35	6,38	8,92	3,41	A+	6,10	5,30	304
MU2-Y 53M (1x2)	20M 8.000	27M 9.000	2,19	2,81	2,12	5,00	5,83	0,54	1,55	2,05	2,35	6,73	8,92	3,23	A+	6,10	5,30	304
	20M 8.000	35M 12.000	1,84	3,16	2,12	5,00	6,41	0,54	1,55	2,05	2,35	6,73	8,92	3,23	A+	6,10	5,30	304
	20M 8.000	53M 18.000	1,40	3,63	2,12	5,00	6,47	0,54	1,54	2,05	2,35	6,69	8,92	3,25	A+	6,10	5,30	304
	27M 9.000	27M 9.000	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
	27M 9.000	35M 12.000	2,27	3,03	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
	27M 9.000	53M 18.000	1,77	3,53	2,12	5,30	6,47	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
	35M 12.000	35M 12.000	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304

Notes Pd = Pdesign CEA = Annual Energy Consumption

OUTDOOR UNIT	INDOOR UNIT		HEATING CAPACITY [KW]		TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
	TO	B	TO	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
MU2-Y 53M (1x1)	20M 8.000	—	2,45	—	1,56	2,50	3,03	0,32	0,67	0,83	1,39	2,90	3,62	3,75	—	—	—	—
	27M 9.000	—	3,00	—	1,56	3,00	3,63	0,32	0,80	1,00	1,39	3,48	4,35	3,75	—	—	—	—
	35M 12.000	—	3,80	—	1,56	3,80	4,60	0,32	1,00	1,20	1,39	4,34	5,20	3,81	—	—	—	—
	53M 18.000	—	5,20	—	1,73	5,20	5,79	0,42	1,35	1,88	1,83	5,87	8,16	3,85	—	—	—	—
	20M 8.000	20M 8.000	2,50	2,50	2,23	5,00	6,04	0,51	1,35	1,88	2,22	5,86	8,16	3,71	TO	4,00	4,30	1505
MU2-Y 53M (1x2)	20M 8.000	27M 9.000	2,32	2,98	2,23	5,30	6,13	0,51	1,43	1,88	2,22	6,21	8,16	3,71	TO	4,00	4,30	1505
	20M 8.000	35M 12.000	2,03	3,47	2,23	5,50	6,36	0,51	1,48	1,88	2,22	6,45	8,16	3,71	TO	4,00	4,30	1505
	20M 8.000	53M 18.000	1,60	4,14	2,23	5,70	6,60	0,51	1,54	1,88	2,22	6,68	8,16	3,71	TO	4,00	4,30	1505
	27M 9.000	27M 9.000	2,79	2,79	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	TO	4,00	4,30	1505
	27M 9.000	35M 12.000	2,39	3,18	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	TO	4,00	4,30	1505
	27M 9.000	53M 18.000	1,86	3,71	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	TO	4,00	4,30	1505
	35M 12.000	35M 12.000	2,79	2,79	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	TO	4,00	4,30	1505

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT